

Почасовые контрольные замеры нагрузок и напряжений

ПО "СЭС"

ПС 35/6 Касево

День	Месяц	Год
18	06	2025

Присоединение	Ед. изм.	Часы																							
		00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00
1	А	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
филиер 6 кВ	А	105,0	98,0	85,0	92,0	99,0	103,0	117,0	131,0	133,0	145,0	147,0	152,0	157,0	166,0	157,0	154,0	153,0	157,0	148,0	135,0	123,0	108,0	105,0	100,0
филиер №9 1 сек.ш.	МВт																								
филиер №9 1 сек.ш.	А	26,0	26,0	22,0	24,0	26,0	27,0	29,0	30,0	32,0	41,0	39,0	41,0	39,0	42,0	40,0	37,0	38,0	40,0	37,0	36,0	33,0	26,0	26,0	25,0
филиер №11 1 сек.ш.	МВт																								
филиер №11 1 сек.ш.	А	27,0	18,0	17,0	20,0	2,0	22,0	30,0	38,0	38,0	36,0	35,0	36,0	41,0	41,0	35,0	38,0	39,0	37,0	33,0	30,0	28,0	26,0	27,0	26,0
филиер №13 1 сек.ш.	МВт																								
филиер №13 1 сек.ш.	А	15,0	19,0	15,0	17,0	19,0	17,0	20,0	19,0	23,0	20,0	21,0	25,0	22,0	23,0	27,0	26,0	24,0	25,0	24,0	21,0	23,0	19,0	17,0	14,0
филиер №15 1 сек.ш.	МВт																								
филиер №15 1 сек.ш.	А	37,0	35,0	31,0	31,0	35,0	37,0	38,0	44,0	40,0	48,0	52,0	50,0	55,0	60,0	55,0	53,0	52,0	55,0	54,0	48,0	39,0	37,0	35,0	35,0
филиер 6 кВ	А	16,0	14,0	11,0	13,0	12,0	14,0	18,0	20,0	21,0	22,0	22,0	20,0	21,0	25,0	23,0	22,0	17,0	23,0	20,0	20,0	17,0	16,0	14,0	15,0
филиер №4 2 сек.ш.	МВт																								
филиер №4 2 сек.ш.	А	23,0	23,0	18,0	20,0	27,0	22,0	24,0	30,0	32,0	35,0	31,0	35,0	35,0	35,0	36,0	33,0	28,0	35,0	26,0	25,0	24,0	23,0	19,0	23,0
филиер №8 2 сек.ш.	МВт																								
филиер №8 2 сек.ш.	А	39,0	37,0	29,0	33,0	34,0	36,0	42,0	50,0	53,0	57,0	53,0	55,0	56,0	60,0	59,0	55,0	45,0	58,0	46,0	45,0	41,0	39,0	33,0	38,0
Ввод №2 яч. 14 на 2 сек.ш.	МВт																								
Напряж 6кВ 1Т 1 сек.ш.	кВ	6,2	6,2	6,2	6,2	6,1	6,1	6,1	6,1	6,1	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,0	6,1	6,1	6,1	6,1	6,2	6,2	6,2
напряж 6кВ 2Т 2 сек.ш.	кВ	6,4	6,4	6,4	6,4	6,3	6,3	6,3	6,3	6,3	6,2	6,2	6,2	6,2	6,2	6,2	6,2	6,2	6,2	6,2	6,3	6,3	6,3	6,3	6,4

Директор ПО СЭС АО "Региональные электрические сети"

И.И. Гарифуллин

Почасовые контрольные замеры нагрузок и напряжений

ПО "СЭС" АО "Региональные электрические сети" ПС 35/6 кВ Касево

День	17
Месяц	12
Год	2025

Присоединение	Ед. изм.	Часы																									
		00:00	01:00	02:00	03:00	04:00	05:00	06:00	07:00	08:00	09:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	
1 фильтр 6 кВ ввод №1 яч. №5 на 1 сек.ш.	А	175,0	164,0	158,0	149,0	143,0	144,0	151,0	157,0	163,0	175,0	180,0	184,0	185,0	190,0	191,0	195,0	195,0	200,0	200,0	205,0	204,0	200,0	24	25	26	27
	МВт											42,0	43,0	43,0	44,0	44,0	46,0	46,0	48,0	50,0	52,0	52,0	50,0	59,0	47,0	44,0	44,0
фильтр №9 1 сек.ш.	А	42,0	40,0	39,0	33,0	30,0	30,0	31,0	35,0	40,0	43,0	42,0	43,0	43,0	44,0	44,0	46,0	46,0	48,0	50,0	52,0	52,0	50,0	59,0	47,0	44,0	44,0
	МВт																										
фильтр 6 кВ	А	52,0	51,0	50,0	49,0	48,0	48,0	48,0	50,0	53,0	55,0	54,0	53,0	55,0	56,0	56,0	57,0	57,0	56,0	55,0	55,0	55,0	53,0	51,0	50,0	49,0	49,0
	МВт																										
фильтр 6 кВ	А	52,0	51,0	50,0	49,0	48,0	48,0	48,0	50,0	53,0	55,0	54,0	53,0	55,0	56,0	56,0	57,0	57,0	56,0	55,0	55,0	55,0	53,0	51,0	50,0	49,0	49,0
	МВт																										
фильтр №13 1 сек.ш.	А	50,0	49,0	48,0	47,0	45,0	43,0	43,0	44,0	45,0	47,0	52,0	55,0	56,0	58,0	61,0	62,0	61,0	62,0	63,0	64,0	62,0	61,0	60,0	65,0	59,0	59,0
	МВт																										
фильтр №15 1 сек.ш.	А	28,0	27,0	23,0	25,0	25,0	26,0	27,0	27,0	29,0	30,0	30,0	31,0	33,0	33,0	31,0	30,0	30,0	31,0	30,0	30,0	30,0	30,0	29,0	28,0	17,0	17,0
	МВт																										
фильтр №4 2 сек.ш.	А	41,0	40,0	39,0	43,0	44,0	45,0	46,0	45,0	42,0	45,0	44,0	46,0	53,0	52,0	52,0	52,0	50,0	49,0	45,0	44,0	44,0	44,0	41,0	41,0	40,0	40,0
	МВт																										
фильтр №8 2 сек.ш.	А	68,0	65,0	63,0	71,0	72,0	70,0	73,0	71,0	73,0	73,0	75,0	78,0	85,0	83,0	82,0	83,0	81,0	80,0	76,0	74,0	74,0	73,0	71,0	69,0	57,0	57,0
	МВт																										
Ввод №2 яч. №14 на 2 сек.ш.	А	6,2	6,19	6,29	6,29	6,08	6,08	6,10	6,12	6,12	6,12	6,13	6,13	6,15	6,18	6,18	6,19	6,19	6,20	6,20	6,20	6,21	6,21	6,20	6,23	6,23	6,23
	кВ	6,4	6,41	6,40	6,31	6,31	6,29	6,30	6,31	6,31	6,31	6,35	6,38	6,38	6,40	6,41	6,42	6,41	6,41	6,42	6,42	6,42	6,42	6,42	6,40	6,43	6,44
Напряж 6кВ ТТ 1 сек.ш.	А																										
	кВ																										
напряж 6кВ 2Т 2 сек.ш.	А																										
	кВ																										

И.о. директора ПО "СЭС" АО "Региональные электрические сети"

И.М. Салихов